FILED
March 02, 2023
Data Center
Missouri Public
Service Commission

Exhibit No. 12

Evergy West – Exhibit 12 SPP December 2022 Winter Storm Elliot Report File No. EA-2022-0328



Working together to responsibly and economically keep the lights on today and in the future.

DECEMBER 2022 WINTER STORM ELLIOTT

C.J. BROWN

DIRECTOR, SYSTEM OPERATIONS








2022 WINTER STORM GRID EMERGENCY

TIMELINE OF OPERATIONAL COMMUNICATIONS: DEC. 19-26, 2022

| Fri. 12/16 to Mon. 12/19 | Tue. 12/20 | Wed. 12/21 | Thu. 12/22 | Fri. 12/23 | Sat. 12/24 | Sun. 12/25 | Mon. 12/26 |
|---|--|--|-----------------------------------|---|---|--|---|
| Fri. 12/16: Internal communication with operations notes upcoming cold weather. Operations | Information with ations notes upcoming I weather. Operations toring conditions with identified needs for arce alerts at that date. Information with identified needs for arce alerts at that date. Information with identified needs for arce alerts at that date. Information with identified needs for arce alerts at that date. Information with identified needs for arce alerts at that date. Information with identified needs for architecture. Information with architecture. Inf | 10:00 SPP Comms. sends Grid Notice of upcoming Resource Advisory | Resource Advisory in effect | Resource Advisory in effect | Conservative Operations in effect | Conservative Operations in effect | Weather Advisory in effect |
| | | | | 08:27 EEA1 declared | 08:29 SPP extends anticipated end of Conservative | | |
| no identified needs for resource alerts at that date. | | | | 10:00 End of EEA | | | 10:00 SPP returns to Normal Operations |
| Mon. 12/19, 13:54 SPP operations issues a | | | | 11:00 Conservative | Operations through 12/25 12:00 | | |
| Cold Weather Advisory to begin on 12/21/22 at 20:00. | | | | Operations declared, anticipated end | | 12:00 Conservative Operations ends but Resource Advisory | |
| Mon. 12/19, 14:30 SPP Communications sends Grid Notice email to all subscribers regarding the upcoming Weather Advisory | | | | 12/25 00:00 | | | |
| | | | | 17:20 EEA1 declared | | | |
| | | | | 20:20 End of EEA. | | in effect until midnight | |
| | | | | Conservative Operations Continues | | | |

Time blocks are not to scale





DRIVERS OF ENERGY EMERGENCY ALERTS

- 1. Generation unavailability
 - Lack of fuel supply
 - Extreme cold weather-related outages
- 2. Record winter energy consumption
 - New record set 12/22/22 @ 18:27: 47,157 MW

ADVANCE PREPARATIONS

- Alerted operators as conditions changed
- Provided advance notification to members committee
- Communicated with Operating Reliability Working Group and provided public notifications as system conditions changed
- Committed gas generation early to help fuel procurement

OTHER NOTABLE CHALLENGES

• **Dec. 20:** SPP began receiving natural gas notifications that flexibility and other non-firm usage of pipelines would be greatly limited through Dec. 28

• Dec. 23:

- SPP Chenal facility transformer malfunctioned and operated on backup generators during the event
- SPP Chenal data center cooling system was inoperable due to low temperatures for 6 hours until system bypass was put in place
- Dec. 23 & 24: Missouri river developed ice block preventing river flow and threatened 1000s of MWs of generation

OPERATIONAL DATA

KEY POINTS FOR ELLIOTT & URI COMPARISON

For SPP, Elliott was not as severe as winter storm Uri (Feb. 2021)


Fewer gas and wind outages in Elliott than Uri

Coal outages and derates were worse in Elliott


While there was no BA directed load shed in Elliott, there was BA load shed potential




TOTAL ACCREDITED CAPACITY BREAKDOWN VS. LOAD 12/23/2022 06:00 ELLIOTT




TOTAL ACCREDITED CAPACITY BREAKDOWN VS. LOAD 12/24/2022 06:00 ELLIOTT



TOTAL ACCREDITED CAPACITY BREAKDOWN VS. LOAD URI




PEAK OBLIGATION VS. DAILY ACCREDITED AVAILABLE CAPACITY ELLIOTT



^{**}This compares the maximum obligation during the time frame (Load + Operating Reserves) to the accredited availability on that day.




AVAILABLE GENERATION IN SPP MARKET ELLIOTT




Average Available Generation

AVAILABLE GENERATION IN SPP MARKET URI



FUEL TYPE CAPACITY BREAKDOWN 12/23/2022 06:00 ELLIOTT



0.01


0.0


0.0

0.0


0.0


FUEL TYPE CAPACITY BREAKDOWN 12/24/2022 06:00 ELLIOTT


























FUEL TYPE CAPACITY BREAKDOWN 12/22-12/24 ELLIOTT (MINIMUM AVAILABLE)






















- Available
- 5-Year Available
- Accredited



URI VS ELLIOTT COAL AVAILABILITY



ElliottAverage throughout event




During Elliott, accredited coal performed below Uri levels by ~2.3GW


- Available
- 5-Year Available
- Accredited

URI VS ELLIOTT GAS AVAILABILITY

Uri During load shed



ElliottAverage throughout event




During Elliott, accredited gas performed above Uri levels by ~8.7 GW


- Available
- 5-Year Available
- Accredited

URI VS ELLIOTT WIND AVAILABILITY






ElliottAverage throughout event



During Elliott, accredited wind performed above Uri levels by ~9 GW


- Available
- 5-Year Available
- Accredited

GENERATING CAPACITY OUTAGES ELLIOTT




COAL BY PRIORITY ELLIOTT


Majority of coal outages were forced or emergency



GAS BY PRIORITY ELLIOTT









FORECAST

SPP LOAD FORECAST ELLIOTT



WIND FORECAST (COLD WEATHER/ICING) VS. ACTUAL ELLIOTT




Forecast Time

- December 20, 2022 7 AM
- December 21, 2022 7 AM
- December 22, 2022 7 AM
- Actual Wind

"Icing" wind forecast performed very well for the event

SYSTEM CONGESTION

OVERVIEW FOR THE CONGESTIONS AT PEAK LOAD




Number of FGs

- Elliott: Max of 35 breeched flowgates, w/50-60 actively managed by Reliability Coordinator and Markets
- Uri: Max of 28 breeched flowgates, w/50-60 actively managed by Reliability Coordinator and Markets

SPP VOLTAGE HEAT MAP ELLIOTT


flows





TOP-DIRECTED LOAD SHED

- Low voltages ultimately resulted in TOP-directed load shed
 - EDE shed appx 25 MW on 12/22 from 21:00 to 21:15 primarily due to the lack of ability to deliver available native resources





NEXT STEPS

Complete post event review and gather lessons learned

Participate as requested in FERC/NERC/MRO inquiry

Continue to support resource adequacy efforts

- IRATF
- SAWG
- RSC





C.J. BROWN DIRECTOR, SYSTEM OPERATIONS

501-614-3569 cbrown@spp.org