

GENERATOR SET DATA

| | | | |
|---------------|-----------|----------|---------|
| MODEL # | QT04524AN | SERIAL # | 4719122 |
| | | | |
| RATED KW | 45 | | |
| RATED KVA | 45 | | |
| PHASE | 1 | | |
| RATED VOLTAGE | 120/240 | | |
| RATED AMPS | 187.5 | | |
| | | | |
| POWER FACTOR | 1 | | |
| HERTZ | 60 | | |
| | | | |
| ALT. R.P.M. | 3600 | | |
| ENGINE RPM | 3600 | | |

FILED
November 7, 2018
Data Center
Missouri Public
Service Commission

TRANSFER SWITCH DATA

| | | |
|----------------|-----------|--|
| SYSTEM VOLTAGE | 120/240 | |
| SERIAL # | 4717682 | |
| MODEL # | RTSE200A3 | |
| RATED AT | 200 AMPS | |
| RATED AT | 240 VOLTS | |
| | | |
| | | |

Lucy Exhibit No. 49
Date 10-23-18 Reporter TR
File No. EC-2018-0376