

FILED  
May 01, 2023  
Data Center  
Missouri Public  
Service Commission

# Exhibit No. 6

Ameren – Exhibit 6  
Mark Peters  
Direct Testimony  
File No. ER-2022-0337

Exhibit No.:  
Issue(s): Production Cost  
Modeling  
Witness: Mark J. Peters  
Sponsoring Party: Union Electric Company  
Type of Exhibit: Direct Testimony  
File No.: ER-2022-0337  
Date Testimony Prepared: August 1, 2022

**MISSOURI PUBLIC SERVICE COMMISSION**

**FILE NO. ER-2022-0337**

**DIRECT TESTIMONY**

**OF**

**MARK J. PETERS**

**ON**

**BEHALF OF**

**UNION ELECTRIC COMPANY**

**D/B/A AMEREN MISSOURI**

**St. Louis, Missouri  
August, 2022**

## TABLE OF CONTENTS

I.	INTRODUCTION .....	1
II.	PURPOSE AND SUMMARY OF TESTIMONY .....	2
III.	PRODUCTION COST MODELING .....	3
IV.	PRODUCTION COST MODEL INPUTS .....	6
V.	REAL-TIME LOAD AND GENERATION DEVIATION and REAL-TIME RSG MAKE WHOLE PAYMENT MARGIN ADJUSTMENTS .....	13
VI.	PERCENTAGE OF TRANSMISSION COST TO BE INCLUDED IN FAC.....	14
VII.	MARKET ENERGY AND CAPACITY SALES REVENUES TO BE INCLUDED IN THE RESRAM AND EXCLUDED FROM THE FAC .....	14

**DIRECT TESTIMONY**

**OF**

**MARK J. PETERS**

**FILE NO. ER-2022-0337**

1 **I. INTRODUCTION**

2 **Q. Please state your name and business address.**

3 A. Mark J. Peters, One Ameren Plaza, 1901 Chouteau Avenue, St. Louis, Missouri  
4 63103.

5 **Q. By whom and in what capacity are you employed?**

6 A. I am employed by Ameren Services Company ("Ameren Services") as a Manager  
7 in the Corporate Planning Analysis Department, where I am responsible for the supervision and  
8 guidance of the group responsible for running production cost model studies used in developing  
9 budgets and financial forecasts, fuel burn projections, emissions estimates, and other generation  
10 station project analyses, and which is used in the preparation of and as evidentiary support for rate  
11 reviews, such as this one.

12 **Q. Please describe your educational and professional background.**

13 A. I received a Bachelor of Arts degree in Liberal Arts & Sciences (Concentration in  
14 Economics) in August of 1985 from the University of Illinois (Urbana-Champaign).

15 I began employment with Illinois Power Company in August of 1985, holding a variety of  
16 roles prior to its acquisition by Ameren Corporation. Since Illinois Power's acquisition, I have  
17 been involved with Ameren's Illinois utility subsidiaries' post-2006 energy supply acquisition  
18 process, the guidance and supervision of a group that provided analytical support to the Ameren

1 Missouri trading group, which is now managed by Ameren Missouri witness Andrew Meyer, and  
2 the guidance of load forecasting and load research activities, in addition to my current duties.

3 **II. PURPOSE AND SUMMARY OF TESTIMONY**

4 **Q. What is the purpose of your direct testimony?**

5 A. The purpose of my direct testimony is to sponsor the determination of the  
6 normalized value for the sum of allowable fuel costs plus the cost of net purchased power, which  
7 was used by Company witness Mitchell Lansford in determining Ameren Missouri's revenue  
8 requirement for this case and in calculating the Net Base Energy Costs ("NBEC") utilized in the  
9 Company's Fuel Adjustment Clause ("FAC"). These costs consist of the delivered cost of nuclear  
10 fuel, coal, oil, and natural gas associated with producing electricity from the Ameren Missouri  
11 generation fleet, plus the variable component of net purchased power.

12 My testimony will also include the determination of:

- 13 1) The real-time load and generation deviation adjustment that has been included in  
14 the determination of NBEC over the last several Ameren Missouri electric rate  
15 reviews;
- 16 2) The level of real-time revenue sufficiency guarantee make-whole payment ("RT  
17 RSG MWP") margins to be include in the net off-system sales component of NBEC  
18 included in witness Meyer's testimony;
- 19 3) The percentage of transmission costs and revenues to be included in the FAC; and  
20 4) The normalized value for market energy and capacity revenues for the High Prairie  
21 and Atchison County Renewable Energy Centers to be included in the base amounts  
22 established in this proceeding for the Company's Renewable Energy Standard Rate  
23 Mechanism ("RESRAM"), and excluded from the NBEC.

1           Company witness Andrew Meyer is also filing direct testimony to address other FAC  
2 components, including net off-system sales revenues which are netted against the costs that I have  
3 modeled, which are used by witness Lansford in determining NBEC.

4           **Q.     Please summarize your testimony and conclusions.**

5           A.     I have determined the following normalized values to be used by witness Lansford  
6 in determining Ameren Missouri's revenue requirement for this case and in calculating the  
7 ("NBEC") utilized in the Company's FAC:

- 8           1)     Fuel costs of \$572.1 million;
- 9           2)     Net purchased power costs of \$50.4 million;
- 10          3)     Real-time load and generation deviation credit adjustment (reduction in NBEC) of  
11                 \$7.7 million; and
- 12          4)     RT RSG MWP Margins of \$2.7 million (reduction in NBEC).

13           I have also determined the normalized market energy and capacity revenues related to the  
14 High Prairie and Atchison County Renewable Energy Centers to be used by witness Lansford in  
15 determining the revenue requirement and in calculating the base amount for the RESRAM are, in  
16 total for both facilities, \$73.1 million for energy and \$1 million for capacity.

17           Finally, I have determined that the generation weighted average locational margin price  
18 ("LMP") to be used in the Company's production cost modeling is \$33.30, and that the appropriate  
19 percentage of transmission costs and revenues to be used in determining NBEC is 4.97%.

### 20                                 **III.           PRODUCTION COST MODELING**

21           **Q.     What is a production cost model?**

22           A.     A production cost model is a computer application used to simulate an electric  
23 utility's generation system and load obligations. One of the primary uses of the production cost

1 model is to develop production cost estimates used for planning and decision making, including  
2 the development of a normalized level of net energy costs upon which a utility's revenue  
3 requirement can be based.

4 "Net energy costs" as used in this testimony are the normalized values for the sum of  
5 allowable fuel costs, including transportation, plus the cost of net purchased power. These are a  
6 subset of the total fuel and net purchased power costs, including transportation and emissions costs  
7 and revenues and net of net off-system sales revenues, which are used to establish NBEC in the  
8 Company's Rider FAC tariff sheets.<sup>1</sup> As noted, the NBEC is discussed in witness Lansford's direct  
9 testimony.

10 **Q. How is PowerSIMM used by Ameren Missouri?**

11 A. PowerSIMM is used by Ameren Missouri to model generation output, and when  
12 compared to load, to model net off-system sales and net purchased power. The results of this  
13 modeling are used for operational, financial, and regulatory purposes.

14 **Q. What are the major inputs to the PowerSIMM model run used for calculating**  
15 **a normalized level of net energy costs?**

16 A. The major inputs are: normalized hourly loads, unit operating characteristics, unit  
17 availabilities, prices for the primary variable cost components (fuel by type and by plant, variable  
18 operating and maintenance costs, opportunity cost of emissions), and the market price of electrical  
19 energy.

---

<sup>1</sup> There are other components of NBEC that are not produced by the production cost modeling, as discussed by witnesses Meyer and Lansford in their direct testimonies.

1           **Q.     What are the major outputs of the PowerSIMM model run used for calculating**  
2 **a normalized level of net energy costs?**

3           A.     The major outputs are: generation output by unit expressed in megawatt-hours  
4 ("MWh"), millions of British thermal units ("MMBtu"), and the cost in dollars; net purchases of  
5 energy, expressed in both MWh and dollars; and net off-system sales of energy, expressed in both  
6 MWh and dollars.

7           **Q.     Please generally describe how net off-system sales and net purchases of energy**  
8 **are determined by the model.**

9           A.     For any given hour, the model increases the generation output for units that have a  
10 dispatch cost below the hourly market price for energy and decreases the output for those units  
11 whose dispatch cost is above the hourly market price. The model accomplishes this while  
12 recognizing the unit operating limits and characteristics, and after the model has determined unit  
13 commitment. In this manner, the model determines the output of each generator in MWh for each  
14 hour. This output is then compared to the load assumption in MWh for each hour to determine  
15 whether there is a net purchase or a net off-system sale for that hour.

16           In that regard, the model emulates the Company's market settlements with the  
17 Midcontinent Independent System Operator, Inc.'s ("MISO") markets. In actual operations, the  
18 Company purchases energy for its entire load from the MISO market and separately sells all of the  
19 MWhs generated by its generating units into the MISO market.<sup>2</sup> However, it is my understanding  
20 that the Federal Energy Regulatory Commission ("FERC") requires that these amounts be netted  
21 against each other for each hour for reporting purposes. This netting results in the recording of

---

<sup>2</sup> The only exception are the MWhs produced by the Atchison County Renewable Energy Center, with that power being sold into the Southwest Power Pool's ("SPP") energy market, since Atchison is connected to the transmission system under SPP's functional control. Those power sales, along with those for the High Prairie Renewable Energy Center, are included in the Company's RESRAM.



1 either a net off-system sale or a net power purchase for that hour, depending on whether the volume  
2 of total sales exceeds total purchases (net off-system sale) or if the volume of total purchases  
3 exceeds total sales (net power purchase). A \$1 increase in off-system sales revenue has the same  
4 impact on NBEC as a \$1 reduction in purchased power expense (and vice versa).

5 **IV. PRODUCTION COST MODEL INPUTS**

6 **Q. What load data assumptions were used in the PowerSIMM model run used for**  
7 **calculating a normalized level of net fuel costs?**

8 A. We used normalized hourly loads, including applicable losses, developed from the  
9 actual loads for the test year of April 1, 2021 through March 31, 2022.

10 **Q. What operational data assumptions were used in the PowerSIMM model run**  
11 **used for calculating a normalized level of net energy costs?**

12 A. Operational data assumptions reflecting the characteristics of the generating units  
13 were used for this purpose, including: unit input/output curve, which calculates the fuel input  
14 required for a given level of generator output; unit minimum and maximum load levels; ramp rates;  
15 minimum up and down times; unit commit status; identification of specific fuel used for startup  
16 and generation, including the ratio of those fuels if more than one for a given unit; emission  
17 limitations, and fuel blending. Schedule MJP-D1 lists the operational data used for this review.

18 **Q. Are there any changes of note in the unit operating characteristics included in**  
19 **the PowerSIMM model as compared to the modeling submitted in the Company's last**  
20 **electric rate review?**

21 A. Yes.

22 First, all units of the Meramec Energy Center have been removed from the modeling to  
23 reflect its retirement by end of year 2022.

1           Secondly, the model assumptions reflect limits on the output of its combustion turbines  
2           sited in the State of Illinois to conform to the emission limits in that State's Climate and Equitable  
3           Jobs Act ("CEJA"), enacted in September 2021.

4           The model assumptions also reflect more limited production of the Rush Island Energy  
5           Center to reflect the reduced operations explained in witness Meyer's direct testimony.

6           Additionally, unit ramp rates, heat rates and minimum load levels were updated to reflect  
7           current operating practice.

8           It should be noted that the normalized output of the High Prairie and Atchison County  
9           Renewable Energy Centers have been excluded from the production cost model, as the revenue  
10          associated with these facilities are excluded from NBEC. Instead, the normalized revenues  
11          associated with these resourced is included in the base amounts established for the RESRAM.

12          **Q.     What unit availability data assumptions were used in the PowerSIMM model**  
13          **run used for calculating a normalized level of net energy costs?**

14          A.     Unit availability data assumptions were developed to annualize planned outages,  
15          unplanned outages and de-ratings. Planned outages are major unit outages that are scheduled in  
16          advance. The length of the scheduled outage depends on the type of work being performed.  
17          Planned outage intervals vary due to factors such as type of unit, unplanned outage rates during  
18          the maintenance interval, and plant modifications. A normalized planned outage length was used  
19          for this rate review, as reflected in Schedule MJP-D2. The lengths of the planned outage  
20          assumptions, except for the Callaway Energy Center, are based on a six-year average of actual  
21          planned outages that occurred between April 1, 2016 and March 31, 2022. The outage assumption  
22          for the Callaway Energy Center was based on an annualized average of the four most recent re-

1 fueling outages: numbers 21 through 24. The unit availability assumptions for the Rush Island  
2 Energy Center units are explained later in my testimony.

3 In addition to the length of the planned outage, the time period when the planned outage  
4 occurs is also important. The planned outage schedule assumption used in modeling Ameren  
5 Missouri's generation with the PowerSIMM model in this proceeding is shown in Schedule MJP-  
6 D3. This assumption was developed in consideration of historical practices and market prices,  
7 whereby such outages are generally scheduled in the spring and fall, when the negative financial  
8 consequences of removing a unit from service are lower.

9 Unplanned outages are short outages when a unit is completely off-line, which are not  
10 scheduled in advance. These outages typically last from one to seven days and occur between the  
11 planned outages. Unplanned outages by definition are unforeseen events whose timing cannot be  
12 predicted, and thus are modeled as random events. The normalized unplanned outage rate  
13 assumption for this proceeding is based on a six-year average of unplanned outages that occurred  
14 between April 1, 2016 and March 31, 2022, and is reflected in Schedule MJP-D4. It should be  
15 noted that the extended forced outage at the Callaway Nuclear Energy Center immediately  
16 following the late 2020 refueling was excluded, as that was considered to be a non-recurring event.

17 A unit de-rate occurs when a generating unit cannot reach its maximum output due to  
18 operational considerations. The magnitude of the de-rating varies based on the operating issues  
19 involved. As with the unplanned outage assumption, these are unforeseen events whose timing  
20 cannot be predicted, and thus are modeled as random events. The de-rate assumption used in this  
21 case is based on a six-year average of de-rates that occurred between April 1, 2016 and March 31,  
22 2022, and is reflected in Schedule MJP-D5.

1           **Q.     What fuel data assumptions were used in the PowerSIMM model run used for**  
2 **calculating a normalized level of net energy costs?**

3           A.     Ameren Missouri's units burn four general types of fuel: nuclear fuel, coal, natural  
4 gas (including landfill gas), and oil. The specific fuels (and the applicable ratio of those fuels if  
5 more than one) used by each generating unit for both normal generation and unit startup are  
6 identified in the model, and an incremental and average cost assumption is developed for each.  
7 The incremental cost assumptions are used by the model in its dispatch logic—determining when  
8 and at what output level a specific unit should run. Average costs represent the accounting costs  
9 incurred for the fuel consumed by generation and are used to calculate the fuel cost for each  
10 generating unit:

- 11           •     The natural gas and oil price assumptions are based on the average daily spot  
12 market prices for the 36-month period ending March 31, 2022, adjusted to remove  
13 the impact of Winter Storm Uri;
- 14           •     The nuclear fuel cost assumption is based on the average nuclear fuel cost  
15 associated with Callaway Refuel 24;
- 16           •     The incremental coal cost assumptions are based on the average spot market prices  
17 for the 36-month period ending March 31, 2022; and
- 18           •     The average (accounting) coal cost assumptions reflect coal and transportation  
19 costs based upon coal and transportation prices that will be effective as of  
20 January 1, 2023.

21           We have not included a cost assumption for landfill gas, as those costs represent Renewable  
22 Energy Standard ("RES") compliance costs and are accounted for in the rebase of operations and

1 maintenance costs reflected in the RESRAM, as addressed by Company witness Lansford in his  
2 direct testimony.

3 **Q. What market energy price assumptions were utilized for the production cost**  
4 **modeling?**

5 A. Consistent with past practice, the price assumptions used to model dispatch were  
6 the average hourly energy prices for the 36-month period ending December 31, 2022, adjusted to  
7 remove the impact of Winter Storm Uri. These prices averaged \$33.30 per MWh, on an around-  
8 the-clock basis. The energy prices for the period of January 1, 2020 through March 31, 2022 are  
9 the actual generation weighted average day-ahead locational marginal LMPs in the MISO energy  
10 market for those Ameren Missouri generating units. Given that the Meramec Energy Center units  
11 will be retired in 2022, they were excluded from this calculation.

Consistent with past practice, the energy prices for the remaining months through the true-  
up are basis-adjusted forward energy prices, which serve as a reasonable proxy until they are  
replaced with actual generation weighted energy prices as part of the true-up in this case.

12 **Q. Please explain why you chose to utilize day-ahead LMPs at the generator**  
13 **nodes.**

14 A. The use of the day-ahead LMPs is consistent with longstanding practice. As  
15 mentioned before, the PowerSIMM model simulates the dispatch of the Company's generators  
16 based on a series of inputs. This dispatching logic is similar to the one followed by the MISO to  
17 determine its day-ahead commitment of all of the generators in its footprint. The result of the  
18 MISO process is, among other things, the determination of individual LMPs for each generator. It  
19 is most appropriate to use the historical prices applicable to Ameren Missouri generation for the  
20 day-ahead markets since day-ahead prices determined the generation levels that produced the vast

1 majority of Ameren Missouri's historic net off-system energy sales. In fact, day-ahead prices  
2 determine about 97% of Ameren Missouri's generation commitment and dispatch.

3 **Q. Please describe the emission limitations placed upon the Illinois based CTGs**  
4 **by CEJA.**

5 A. In September 2021, the State of Illinois enacted CEJA. Provisions of this Act limit  
6 the level of emissions that a specific generating unit can produce over any rolling twelve-month  
7 period of time to no more than the annual average for that same emission, produced by that same  
8 unit, over Calendar Years 2018-2020.

9 **Q. How did you model these limits?**

10 A. Given that emissions are directly correlated to unit output, we modeled these limits  
11 by placing maximum MWh limits on each individual unit corresponding to the annual average for  
12 the 2018-2020 time period that was used to establish the CEJA limits. These annual limits were  
13 then allocated to individual months.

14 **Q. Please describe how the operating limits placed upon the Rush Island Energy**  
15 **Center have been modeled.**

16 A. The expected operation of the Rush Island Energy Center is described in the Direct  
17 Testimony of witness Meyer. Our goal is to emulate the expected operations of the station.

18 To reasonably emulate those expected operations, for those months where the units are not  
19 expected to operate (October, November, March, April and May), the units' output was limited to  
20 zero.

21 For those months where the expected operations indicate that the units would be expected  
22 to operate, the unit maximums were adjusted to match a reasonably expected operating profile.  
23 For January, February and December, one unit was set to a maximum of 602 MW and the second

1 unit to 300. For the summer months of June, July, August and September, these limits were set to  
2 300 for both units.

3 Attempting to model forced outage rates on units whose output is already significantly  
4 restricted with both maximum generation constraints, and limits to their economic maximums, is  
5 likely to distort the expected output. As such, forced outage rates for these units were set to zero.

6 I believe that this method of modeling the Rush Island units provides a reasonable  
7 representation of the net output, fuel cost and associated off-system sales revenue for these units  
8 during the period for which rates will be in effect. The results of our modeling also conform with  
9 the operations described by witness Meyer. We will update the modeling as part of the true-up to  
10 incorporate the operating parameters established by the court.

11 **Q. Are there costs and revenues other than those established by the PowerSIMM**  
12 **production cost model which should be considered in the determination of NBEC?**

13 A. Yes. In addition to the real-time load and generation deviation and RT RSG MWP  
14 margin adjustments discussed below, there are other costs and revenues that should be considered  
15 in determining NBEC, which are addressed in witness Meyer's and witness Lansford's direct  
16 testimonies.

17 **Q. Please list the items that are modeled in PowerSIMM that should be trued-up**  
18 **using data as of the end of the anticipated true-up date in this rate review.**

19 A. The following PowerSIMM input assumptions should be updated as of the  
20 applicable true-up date:

- 21 • Ameren Missouri's normalized retail kilowatt-hour ("kWh") sales and distribution  
22 line losses;
- 23 • Coal, nuclear, natural gas, and oil costs;

- 1 • Unit availability factors, including Callaway refueling;
- 2 • Energy prices;
- 3 • Known and measurable changes to unit operating characteristics, if any;
- 4 • Known and measurable changes in emission limitations; and
- 5 • Known and measurable changes in unit operation limitations for the Rush Island
- 6 Energy Center, if any.

7 **V. REAL-TIME LOAD AND GENERATION DEVIATION and REAL-TIME RSG**  
8 **MAKE WHOLE PAYMENT MARGIN ADJUSTMENTS**

9 **Q. Please describe how the real-time load and generation deviation was**  
10 **calculated.**

11 A. The deviation was calculated in a manner consistent with that used in File No. ER-  
12 2021-0240, Ameren Missouri's last rate review, using data for the 36 months ending March 31,  
13 2022. Consistent with past practice, the combustion turbine generators ("CTGs") and the Taum  
14 Sauk Energy Center were excluded. Additionally, all units at the Meramec Energy Center were  
15 excluded, as they are being retired this year.

16 Consistent with past practice, we intend to update this amount as part of the true-up process.

17 **Q. Please describe how the RT RSG MWP margins were calculated?**

18 A. These margins were calculated in a manner consistent with that used in the true-up  
19 in File No. ER-2021-0240, Ameren Missouri's last rate review, using market settlement and fuel  
20 data for the 36 months ending March 31, 2022, with the exception that Meramec CTG1 and  
21 Meramec CTG2 were excluded due to retirements.

22 Consistent with past practice, we intend to update this amount as part of the true-up process.



1       **VI.           PERCENTAGE OF TRANSMISSION COST TO BE INCLUDED IN FAC**

2           **Q.       With respect to transmission charges recorded in Account 565 and**  
3 **transmission revenues recorded in Account 456.1, have you determined what portion of these**  
4 **charges should be included in the determination of NBEC used to determine the Base Factors**  
5 **("BF") in Rider FAC?**

6           A.       Yes. I have determined that amount to be 4.97%. Those amounts excluded from the  
7 calculation of NBEC and BF should be included in base rates.

8           **Q.       Is this the same percentage that should be utilized to determine the portion of**  
9 **total transmission charges to be included in the FAC in any given period?**

10          A.       Yes.

11          **Q.       How was the 4.97% determined?**

12          A.       4.97% is the result obtained by dividing the total MWh of net purchased power in  
13 the production cost model run for this case by the total load assumption used in that model. This  
14 calculation is consistent with that utilized in the true up for File No. ER-2014-0258, and the true  
15 up in each rate review since.

16 **VII.           MARKET ENERGY AND CAPACITY SALES REVENUES TO BE INCLUDED**  
17 **IN THE RESRAM AND EXCLUDED FROM THE FAC**

18          **Q.       What is the level of market energy sales revenue that is appropriate to include**  
19 **in the base amount established for the RESRAM?**

20          A.       I have determined that the normalized market energy sales revenues to be used in  
21 calculating the base amount for the RESRAM are \$73.1 million. This value was obtained by  
22 multiplying the profiled hourly unit output for the High Prairie and Atchison Renewable Energy

1 Centers by the applicable hourly LMPs. These LMPs are the same LMPs that were used in our  
2 production cost modeling.

3 This same amount is excluded from the calculation of NBEC as required by Rider FAC.

4 **Q. What is the level of capacity sales revenue that is appropriate to include in the**  
5 **base amount of the RESRAM?**

6 A. I have determined that the normalized capacity sales revenues to be used in  
7 calculating the base amount of the RESRAM to be \$1 million. This value was determined by taking  
8 the UCAP value for the High Prairie Renewable Energy Center for the most recent MISO capacity  
9 auction and multiplying that value by the average clearing price for the last 3 MISO auctions, for  
10 zone 5, where the facility is located.

11 This same amount is excluded from the calculation of NBEC as required by Rider FAC.

12 **Q. Why did you not include a capacity revenue value for the Atchison Renewable**  
13 **Energy Center?**

14 A. Atchison is located in the Southwest Power Pool, which does not have a capacity  
15 market. Ameren Missouri has not received any capacity revenues related to this facility since its  
16 in-service date.

17 **Q. Does this complete your direct testimony?**

18 A. Yes, it does.

Unit Name	Minimum - Net MW	12 Month Avg Net MW	Must Run	Ramp	Minimum	Minimum	Primary Fuel Type	EDF	A
				Rate MW/Hr	Up Time Hours	Down Time Hours			
Callaway	1,190	1,217	Yes	--	--	6	Nuclear	1.000	--
Labadie 1	240	607	No	480	72	72	PRB Coal	0.976	729.3
Labadie 2	240	607	No	480	72	72	PRB Coal	0.976	840.6
Labadie 3	240	607	No	300	72	72	PRB Coal	0.976	866.4
Labadie 4	240	607	No	480	72	72	PRB Coal	0.976	727.5
Rush 1	225	602	No	300	72	72	PRB Coal	0.949	667.3
Rush 2	225	602	No	300	72	72	PRB Coal	0.949	####
Sioux 1	200	430	No	240	72	72	PRB/IL Coal	1.035	514.9
Sioux 2	200	430	No	240	72	72	PRB/IL Coal	1.035	688.0
Audrain CT 1	62	82	No	--	2	2	Natural Gas	1.000	172.9
Audrain CT 2	62	82	No	--	2	2	Natural Gas	1.000	172.9
Audrain CT 3	62	82	No	--	2	2	Natural Gas	1.000	172.9
Audrain CT 4	62	82	No	--	2	2	Natural Gas	1.000	172.9
Audrain CT 5	62	82	No	--	2	2	Natural Gas	1.000	172.9
Audrain CT 6	62	82	No	--	2	2	Natural Gas	1.000	172.9
Audrain CT 7	62	82	No	--	2	2	Natural Gas	1.000	172.9
Audrain CT 8	62	82	No	--	2	2	Natural Gas	1.000	172.9
Fairgrounds CT	60	60	No	--	2	1	Oil	1.000	179.0
Goose Creek CT 1	50	81	No	--	2	2	Natural Gas	1.000	259.1
Goose Creek CT 2	50	81	No	--	2	2	Natural Gas	1.000	259.1
Goose Creek CT 3	50	81	No	--	2	2	Natural Gas	1.000	259.1
Goose Creek CT 4	50	81	No	--	2	2	Natural Gas	1.000	259.1
Goose Creek CT 5	50	81	No	--	2	2	Natural Gas	1.000	259.1
Goose Creek CT 6	50	81	No	--	2	2	Natural Gas	1.000	259.1
Kinmundy CT 1	77	112	No	--	2	4	Natural Gas	1.000	269.6
Kinmundy CT 2	77	112	No	--	2	4	Natural Gas	1.000	269.6
Meramec CT 1									
Meramec CT 2									
Mexico CT	60	60	No	--	1	1	Oil	1.000	193.9
Moberly CT	60	60	No	--	1	1	Oil	1.000	175.3
Moreau CT	60	60	No	--	1	1	Oil	1.000	144.5
Peno Creek CT 1	51	51	No	--	1	1	Natural Gas	1.000	117.8
Peno Creek CT 2	51	51	No	--	1	1	Natural Gas	1.000	117.8
Peno Creek CT 3	51	51	No	--	1	1	Natural Gas	1.000	117.8
Peno Creek CT 4	51	51	No	--	1	1	Natural Gas	1.000	117.8
Pinkneyville CT 1	42	42	No	--	1	1	Natural Gas	1.000	91.1
Pinkneyville CT 2	42	42	No	--	1	1	Natural Gas	1.000	91.1
Pinkneyville CT 3	42	42	No	--	1	1	Natural Gas	1.000	91.1
Pinkneyville CT 4	42	42	No	--	1	1	Natural Gas	1.000	91.1
Pinkneyville CT 5	39	39	No	--	1	1	Natural Gas	1.000	174.0
Pinkneyville CT 6	39	39	No	--	1	1	Natural Gas	1.000	174.0
Pinkneyville CT 7	39	39	No	--	1	1	Natural Gas	1.000	174.0
Pinkneyville CT 8	39	39	No	--	1	1	Natural Gas	1.000	174.0
Raccoon Creek CT 1	42	82	No	--	2	2	Natural Gas	1.000	286.2
Raccoon Creek CT 2	42	82	No	--	2	2	Natural Gas	1.000	286.2
Raccoon Creek CT 3	54	82	No	--	2	2	Natural Gas	1.000	286.2
Raccoon Creek CT 4	42	82	No	--	2	2	Natural Gas	1.000	286.2
Venice CT 2	52	52	No	--	1	1	Natural Gas	1.000	120.8
Venice CT 3	130	178	No	--	2	4	Natural Gas	1.000	535.0
Venice CT 4	130	178	No	--	2	4	Natural Gas	1.000	535.0
Venice CT 5	77	112	No	--	2	4	Natural Gas	1.000	230.0
Maryland Hts (Fred Weber)	10	8.0	Yes	--	1	1	Landfill Gas	1.000	--
Ofallon	Modeled using fixed profile								
Lambert	Modeled using fixed profile								
BJC	Modeled using fixed profile								
High Prairie	Modeled using fixed profile								
Atchison	Modeled using fixed profile								
Osage	Modeled using fixed profile								
Keokuk	Modeled using fixed profile								
Taum Sauk 1	--	200	No	--	--	--	Pumped Storage	--	--
Taum Sauk 2	--	200	No	--	--	--	Pumped Storage	--	--

<u>Unit Name</u>	<u>Minimum - Net MW</u>	<u>12 Month Avg. Net MW</u>	<u>Must Run</u>	<u>Ramp Rate MW/Hr</u>	<u>Minimum Up Time Hours</u>	<u>Minimum Down Time Hours</u>	<u>Primary Fuel Type</u>	<u>Input / Output</u>	
								<u>EDF</u>	<u>A</u>

Note: # 1 Input Output equation:  $mmbtu = ( A + B \times P_{net} + C \times P_{net}^2 ) \times EDF$ , where  $P_{net}$  = Net power level

## NORMALIZED PLANNED OUTAGES

Actual	Mar-Dec					Jan-Feb		Total (hrs)	Total (days)	Total (annualized days)
	2016 (hrs)	2017 (hrs)	2018 (hrs)	2019 (hrs)	2020 (hrs)	2021 (hrs)	2022 (hrs)			
Labadie 1	160		169	2,215				2,544		
Labadie 2	757		70	2,137				2,964		
Labadie 3	7	1,207	2,724			438		4,375		
Labadie 4	1,873					605		2,479		
<b>Labadie 1-4</b>								<b>12,362</b>	<b>515</b>	<b>86</b>
Rush Island 1			2,026		664	700		3,390		
Rush Island 2	2,355		455		536			3,346		
<b>Rush 1-2</b>								<b>6,735</b>	<b>281</b>	<b>47</b>
Sioux 1	2,378				1,724	695		4,798		
Sioux 2		1,947			639	1,561		4,148		
<b>Sioux 1-2</b>								<b>8,946</b>	<b>373</b>	<b>62</b>

Callaway

Refuel Days	
Refuel 21	38.5
Refuel 22	60.0
Refuel 23	47.6
Refuel 24	55.8
Average	50.5

RC PO Year	PO Days
12/18	33.6

\* Annualized Refuel Outage Length = Avg Days / Refuel Outage x 2/3

	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC
Mws	1 8 15 22	29 5 12 19	26 5 12 19 26	2 9 16 23	30 7 14 21	28 4 11 18 25	2 9 16 23	30 6 13 20 27	3 10 17 24	1 8 15 22	29 5 12 19 26	3 10 17 24
CAL 1										Callaway 1		
RUSH 1										Rush 1		
RUSH 2												
LAB 1			Labadie 1									
LAB 2												
LAB 3												
LAB 4												
SX 1				Sioux 1								
SX 2												
	1 8 15 22	29 5 12 19	26 5 12 19 26	2 9 16 23	30 7 14 21	28 4 11 18 25	2 9 16 23	30 6 13 20 27	3 10 17 24	1 8 15 22	29 5 12 19 26	3 10 17 24
	JAN	FEB	MAR	APR	MAY	JUN	JUL	AUG	SEP	OCT	NOV	DEC

Cal 1 Sep 30 1AM 33.6  
Nov 2 4:35PM

Days 808 Hours

Rush 1 Oct 7 1AM 46.8  
Nov 22 7:33PM

Days L1 86 12  
R1 47 7  
S1 62 9

Lab 1 Mar 11 1AM 85.8  
Jun 5 9:18PM

Days

Sx 1 Apr 1 1AM 62.1  
Jun 2 3:57AM

Days

## Normalized Unplanned Outage Rates - Full Outages

	Mar-Dec						Jan-Feb	<b>Weighted Average</b>
	<b><u>2016</u></b>	<b><u>2017</u></b>	<b><u>2018</u></b>	<b><u>2019</u></b>	<b><u>2020</u></b>	<b><u>2021</u></b>	<b><u>2022</u></b>	
Callaway 1	0.0%	3.6%	0.0%	0.2%	4.5%	0.0%	5.7%	<b>1.6%</b>
Labadie 1	11.1%	5.1%	3.7%	1.4%	2.5%	5.4%	0.0%	<b>4.7%</b>
Labadie 2	4.9%	7.1%	6.0%	5.0%	2.7%	4.7%	10.5%	<b>5.2%</b>
Labadie 3	13.6%	6.2%	5.5%	2.8%	5.5%	7.2%	0.0%	<b>6.6%</b>
Labadie 4	1.7%	5.4%	5.5%	6.7%	10.0%	6.3%	5.2%	<b>6.1%</b>
Rush Island 1	5.6%	5.6%	5.6%	7.9%	5.5%	5.3%	8.7%	<b>5.9%</b>
Rush Island 2	4.2%	6.2%	1.2%	9.1%	4.1%	8.8%	3.7%	<b>5.6%</b>
Sioux 1	10.8%	11.1%	15.0%	12.9%	11.2%	16.1%	10.0%	<b>12.9%</b>
Sioux 2	10.2%	8.6%	6.4%	32.0%	6.8%	3.5%	0.8%	<b>12.4%</b>

## Normalized Derating

	Mar-Dec						Jan-Feb	Weighted
	<u>2016</u>	<u>2017</u>	<u>2018</u>	<u>2019</u>	<u>2020</u>	<u>2021</u>	<u>2022</u>	<u>Average</u>
Callaway 1	1.5%	1.3%	0.4%	1.2%	0.4%	0.1%	0.2%	<b>0.8%</b>
Labadie 1	1.4%	4.0%	2.0%	2.1%	3.0%	3.1%	0.5%	<b>2.6%</b>
Labadie 2	1.3%	1.6%	1.5%	4.2%	1.6%	0.4%	2.9%	<b>1.8%</b>
Labadie 3	2.8%	1.7%	1.9%	1.9%	3.4%	1.6%	0.6%	<b>2.2%</b>
Labadie 4	1.1%	1.7%	1.2%	4.7%	2.7%	1.3%	3.6%	<b>2.2%</b>
Rush Island 1	4.7%	3.8%	2.1%	2.6%	1.7%	2.7%	2.0%	<b>2.9%</b>
Rush Island 2	10.0%	1.7%	1.6%	2.3%	0.7%	2.9%	2.4%	<b>3.0%</b>
Sioux 1	0.1%	1.1%	0.5%	1.1%	2.8%	4.8%	0.9%	<b>1.7%</b>
Sioux 2	3.3%	3.5%	0.2%	1.5%	2.3%	2.4%	4.1%	<b>2.2%</b>



**BEFORE THE PUBLIC SERVICE COMMISSION  
OF THE STATE OF MISSOURI**

In the Matter of Union Electric Company    )  
d/b/a Ameren Missouri’s Tariffs to Adjust    )            Case No. ER-2022-0337  
Its Revenues for Electric Service.         )

**AFFIDAVIT OF MARK J. PETERS**

**STATE OF MISSOURI    )**  
  )**ss**  
**CITY OF ST. LOUIS     )**

Mark J. Peters, being first duly sworn states:

My name is Mark J. Peters, and on my oath declare that I am of sound mind and lawful age; that I have prepared the foregoing *Direct Testimony*; and further, under the penalty of perjury, that the same is true and correct to the best of my knowledge and belief.

   /s/ Mark J. Peters     
Mark J. Peters

Sworn to me this 1<sup>st</sup> day of August, 2022.