

06/11/2007
17:40:42

Platte-Clay Electric Co-op Inc
***** INSTALL POWER MONITOR *****

SO: 410543

Requested for: 06/11/2007
Entered by: JARED4

2036-0003
10123 COUNTY RD N
EXCELSIOR SPRINGS MO 64024
J FERRIL SOLD CLAY CO TRAILER

District: TC
Route Seq: 14/0
Area:

Block Lot

Transformer No: 15477
Size: 5

member having problem with voltage flickering

67849-001
ROOF, GARY
PO BOX 153
EXCELSIOR SPRINGS MO
64024

H: 816 630-2201
W: 816 564-1263

Lights

Active Inactive
1 0

***** Meter Information *****

	Meter Company No.	Meter Mfg No.	Reading:
Electric	10560006	15855068	

***** Return Information *****

Return S/O -Yes

Work completed by: #31 [Signature] Date: 7/2/07

Serviceman comments: CHANGED OUT METER LOOP -
FIXED PROBLEM?

