

Evergy Missouri Metro  
Case Name: 2022 Evergy MO Metro Rate Case  
Case Number: ER-2022-0129

Requestor Geoff Marke -  
Response Provided April 01, 2022

Question:2116

Do any of Evergy's existing AMI meters (or "old" AMI meters) possess the ability to remotely disconnect customers? If so, how many of Evergy's currently deployed AMI meters possess the ability to remotely disconnect customers and how many do not?

**RESPONSE:** (do not edit or delete this line or anything above this)

**Confidentiality:** PUBLIC

**Statement:** This response is Public. No Confidential Statement is needed.

**Response:**

No, the "old" AMI meters that are being replaced currently don't have remote disconnect capability. However, during our original deployments there were some SD meters installed on commercial accounts, high move-in/out locations, and the rural areas of the territory. Currently EMM has approximately 179,000 SD meters and EMW has 188,887 SD Meters.

**Information provided by:** Corey Paczosa

**Attachment(s):**

**Missouri Verification:**



I have read the Information Request and answer thereto and find answer to be true, accurate, full and complete, and contain no material misrepresentations or omissions to the best of my knowledge and belief; and I will disclose to the Commission Staff any matter subsequently discovered which affects the accuracy or completeness of the answer(s) to this Information Request(s).

Signature /s/ *Brad Lutz*  
Director Regulatory Affairs