


WPC - Camden  
Big Island  
ID NO 2174

mo 0123013



STATE OF MISSOURI  
**DEPARTMENT OF NATURAL RESOURCES**

Mel Carnahan, Governor • Stephen M. Mahfouz, Director

DIVISION OF ENVIRONMENTAL QUALITY

Jefferson City Regional Office

210 Hoover Road P.O. Box 176 Jefferson City, MO 65102-0176

(573)751-2729

FAX (573)751-0014

**FILED<sup>2</sup>**

APR 02 2007

Missouri Public  
Service Commission

January 5, 1999

Big Island Homeowners Association, Inc.  
ATTN: Reggie Golden  
P.O. Box 328  
Longmont, CO 80501

Dear Applicant:

Your application for wastewater works to serve the Big Island has been approved by the Department of Natural Resources as evidenced by Construction Permit Number 26-3081 which is enclosed with this letter.

This permit will expire one year from the date of issuance unless justification for extension is presented thirty (30) days prior to expiration. The applicant must show that there have been no substantial changes in the project.

In addition to the requirements for a construction permit, land disturbance activities of five acres or more require a Missouri State Operating Permit to discharge stormwater (10 CSR 20-6.200). The permit requires best management stormwater practices. To obtain this permit, submit Forms E and G and a permit fee of \$150 to the Permits Unit Chief, Department of Natural Resources, Water Pollution Control Program, P.O. Box 176, Jefferson City, Missouri 65102.

Following completion of construction, the enclosed application shall be completed and returned to the Department of Natural Resources, Jefferson City Regional Office, P.O. Box 176, Jefferson City, Missouri 65102. The state operating permit must be obtained prior to discharging wastewater effluent from this facility.

If you have any questions, please contact Keith Forck at the Jefferson City Regional Office at (573) 751-2729.

Sincerely,

JEFFERSON CITY REGIONAL OFFICE

Robert H. Hentges  
Regional Director

RHH:kfl

Enclosures

c: Water Pollution Control Program  
Lake Professional Engineering Services, Inc.

ER Exhibit No. 86  
Case No(s) W02060052/W02007-027  
Date 3-2-07 Rptr PE

STATE OF MISSOURI  
DEPARTMENT OF NATURAL RESOURCES

MISSOURI CLEAN WATER COMMISSION

WPC - Camden  
Big Island  
ID NO 2174

Construction Permit No. 26-3081  
River Reach No: 10290110-03-00



## CONSTRUCTION PERMIT

The Missouri Department of Natural Resources hereby issues a permit to:

Big Island Homeowners  
ATTN: Reggie Golden  
P.O. Box 328  
Longmont, CO 80501

for the construction of (describe facilities):

1000 and 1500 gallon septic tanks with .5 to 1 horsepower effluent pumps designed for 10 gallons per minute at 140 to 170 feet of total dynamic head, 2000 linear feet of two-inch PVC pressure pipe, 7200 linear feet of three-inch PVC pressure pipe, 3400 linear feet of four-inch PVC pressure pipe, air release valves, ten feet by forty feet by six feet deep recirculation tank with four one-horsepower pumps - each designed for fifty gallons per minute

Permit Conditions:

(NONE)

Construction of such proposed facilities shall be in accordance with the provisions of the Missouri Clean Water Law, Chapter 644, RSMo. and regulations promulgated thereunder, or this permit may be revoked by the Department of Natural Resources.

As the Department of Natural Resources does not examine structural features of design or the efficiency of mechanical equipment, the issuance of this permit does not include approval of these features.

A representative of the Department may inspect the work covered by this permit periodically during construction. Issuance of an operating permit by the Department will be contingent on the work substantially adhering to the approved plans and specifications.

This permit applies only to the construction of wastewater treatment facilities; it does not apply to other environmentally regulated areas.

January 5, 1999 *QBF*

Effective Date

*John A. Young*  
Director, Division of Environmental Quality

January 5, 2000

Expiration Date  
\$500.00 Rec'd. Check No. 1011

*[Signature]*  
Director of Staff, Clean Water Commission or Designee

Big Island  
January 5, 1999  
Page 2

**FACILITY DESCRIPTION (CONTINUED):**

at fifty-one feet of total dynamic head, 120 feet by 46 feet recirculating sand filter bed, 1000 gallon chlorine contact chamber, and all the necessary appurtenances to make the facilities complete and usable. This facility is to serve eighty homes in Big Island with a design flow of 22,525 gallons per day. Legal Description: NW1/4, NW1/4, SW1/4, Sec. 6, T38N, R17W, Camden County, Missouri.